

# HOMOSASSA

## SPECIAL WATER DISTRICT

### Annual Drinking Water Quality Report for 2024

Florida Department of Environmental Protection Public Water System ID # 6090828

We're pleased to provide you with this year's Annual Water Quality Report. The report is designed to inform you about the water and services we deliver to you every day. Our goal is to provide you with a dependable supply of quality drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect your water resources. We are committed to ensuring the quality of your water. We are pleased to report that your drinking water meets all federal and state requirements.

The source of our water is groundwater from four wells located in the community. The wells draw from the Floridan aquifer, one of the world's most protected sources. Our water is chlorinated for disinfection purposes. In 2024, the Florida Department of Environmental Protection (DEP) performed a Source Water Assessment on our system and a search of the data sources indicated no potential sources of contamination near our wells. The assessment results are available on the DEP SWAPP website at <https://prodapps.dep.state.fl.us/swapp/>. Our water system also conducted an inventory assessment of our service line plumbing materials in 2024 as part of Federal and State efforts to reduce Lead exposure to the public. The 'Lead Service Line Inventory' results are available for your review by contacting our main phone number shown in the following paragraph. The materials survey inventory identified no lead service lines in your water system. Additional information about reducing your exposure to lead from household plumbing material is provided on page two of this report or by contacting our utility office. If you have any questions about this report or concerning your water utility please contact Justin Ingold at (352) 628-3740, during normal business hours. We encourage our valued customers to be informed about their water utility.

The Special Water District monitors for constituents in your drinking water according to Federal and State laws, rules and regulations. Except where indicated otherwise, this report is based on the results of our monitoring for the period of January 1 to December 31, 2024. Data obtained before January 1, 2024, and presented in this report are from the most recent testing performed in accordance with the laws, rules and regulations.

| WATER QUALITY TEST RESULTS FOR HOMOSASSA SWD        |                             |                       |                        |  |                             |             |                                |  |
|---|-----------------------------|-----------------------|------------------------|--|-----------------------------|-------------|--------------------------------|--|
| Inorganic Contaminants                              |                             |                       |                        |  |                             |             |                                |  |
| Contaminant and Unit of Measurement                 | Dates of Sampling (mo./yr.) | MCL Violation         | Level Detected         | Range of Results                       | MCLG                        | MCL         | Likely Source of Contamination |  |
| Nitrate (as Nitrogen)                               | (ppm)                       | May '23               | No                     | 0.95                                   | 0.51 - 0.95                 | 10          | 10                             | Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits            |
| Sodium  | (ppm)                       | May '23               | No                     | 5.1                                    | 3.7 - 5.1                   | N/A         | 160                            | Salt water intrusion; leaching from soil   |
| Stage 2 Disinfectants and Disinfection By-Products  |                             |                       |                        |  |                             |             |                                |  |
| Disinfectant or Contaminant and Unit of Measurement | Dates of Sampling (mo./yr.) | MCL or MRDL Violation | Level Detected         | Range of Results                       | MCLG or MRDLG               | MCL or MRDL | Likely Source of Contamination |  |
| Chlorine  | (ppm)                       | 2024                  | No                     | 1.0                                    | 0.9 - 1.2                   | MRDLG = 4   | MRDL = 4.0                     | Water additive used to control microbes  |
| Haloacetic Acids (five) (HAA <sub>5</sub> )         | (ppb)                       | Aug '23               | No                     | 2.39                                   | 1.83 - 2.39                 | N/A         | MCL = 60                       | By-product of drinking water disinfection  |
| Total trihalomethane (TTHM)                         | (ppb)                       | Aug '23               | No                     | 14.95                                  | 11.98 - 14.95               | N/A         | MCL = 80                       | By-product of drinking water disinfection  |
| Lead and Copper (Tap Water)                         |                             |                       |                        |  |                             |             |                                |  |
| Contaminant and Unit of Measurement                 | Dates of Sampling (mo./yr.) | AL Violation          | 90th Percentile Result | No. of Sampling Sites Exceeding the AL | Range of Tap Sample Results | MCLG        | AL (Action Level)              | Likely Source of Contamination   |
| Copper (tap water) (ppm)                            | Jun '23                     | No                    | 0.31                   | 0                                      | ND - 0.33                   | 1.3         | 1.3                            | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |

In the table presented you may find unfamiliar terms and abbreviations. To help you better understand these terms we have provided the following definitions (please note not all definitions may pertain to your report):

- **Action Level (AL)** – the concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
- **Maximum Contaminant Level (MCL)** - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

- **Maximum Contaminant Level Goal (MCLG)** - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **Maximum Residual Disinfectant Level (MRDL)** - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial growth.
- **Maximum Residual Disinfectant Level Goal (MRDLG)** – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.
- **ND** – This abbreviation means not detected and indicates that the substance was not found by laboratory analysis.
- **Parts per million (ppm) or milligrams per Liter (mg/L)** - one part of analyte (by weight) to 1 million parts of water sample (by weight).
- **Parts per billion (ppb) or micrograms per Liter (ug/L)** - one part of analyte (by weight) to 1 billion parts of water sample (by weight).
- **Picocurie per liter (pCi/L)** - measure of the radioactivity in water.

### What does this mean?

Due to an administrative oversight we failed to collect the required nitrate and nitrite samples in 2024, resulting in a monitoring violation. The concentration of these contaminants can change quickly over time, therefore we cannot tell you if a health risk occurred. Infants below the age of six months who drink water containing nitrate, or nitrite in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue baby syndrome. Upon the discovery of the oversight, we collected samples in 2025 and the results were satisfactory. We have implemented a better tracking system to prevent this from happening in the future.

Lead can cause serious health effects in people of all ages, especially pregnant women, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. We are responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. We routinely conduct Lead and Copper tap sample monitoring at selected homes within your community as required by State and Federal regulations, you may contact us to review these results. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes.

If your water system has identified a lead service line or galvanized service line requiring replacement, you may need to flush your pipes for a longer period. If you are concerned about lead and wish to have your water tested you can contact one of the local home & building inspection services; the Florida Department of Environmental Protection for a list of certified laboratories (<https://floridadep.gov/dear/florida-dep-laboratory/content/nelap-certified-laboratory-search>; phone # (850) 245-2118 or email [Public.Services@FloridaDEP.gov](mailto:Public.Services@FloridaDEP.gov)); or one of the mail in services that offers analyses through a qualified laboratory (such as <https://aellab.com/product/order-test-kits/> or <https://mytapscore.com/collections/city-water-test-kits>). We do not endorse, nor recommend, any testing service over another, cost will vary by provider. Additional information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals, and in some cases radioactive material, and can pick up substances resulting from the presence of animals or human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which may be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. The FDA (Food & Drug Administration) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care providers about their drinking water. EPA/CDC (Center for Disease Control) guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are also available from the Safe Drinking Water Hotline (800-426-4791).



We are committed to ensuring the quality of your water. If you have any questions or concerns about information provided, please feel free to contact us.